

CITY AND INDUSTRIAL DEVELOPMENT CORPORATION OF MAHARASHTRA LIMITED

(CIN - U99999 MH 1970 SGC - 014574)

REGD. OFFICE:

"NIRMAL", 2nd Floor, Nariman Point,
Mumbai - 400 021.
PHONE : 00-91-22-6650 0900
FAX : 00-91-22-2202 2509

HEAD OFFICE:

CIDCO Bhavan, CBD Belapur,
Navi Mumbai - 400 614.
PHONE: 00-91-22-6791 8100
FAX : 00-91-22-6791 8166

No. CIDCO/FIRE/HQ/2024/1002

Dated: 23-09-2024

FIRE SAFETY CERTIFICATE

Certified that the **SHREE SWAMINARAYAN GURUKUL INTERNATIONAL SCHOOL (SCHOOL BLOCK -A)** at NH-4 Kandroli Village, Asarevadi Road, Chowk Post, Ta. Khalapur, Dist.Raigad Maharastra – 410206 comprised of **0** basement(s) and **G+2** (upper floors) owned by SHREE SWAMINARAYAN GURUKUL, Hyderabad (Trust) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on **23-09-2024** in the presence of **Sadhu Vishvmangaldas** and that the building/ premises is fit for occupancy upto classes **X** With effect from **23-09-2024** for a period of **23-09-2025** year in accordance with rule and subject to compliance of specific conditions as appended: -

1. In build Fire Fighting System Should be kept in good working condition all the time.
 2. As per the Maharashtra Fire Prevention & Life Safety Act, 2006 it is statutory requirement to check the in-built fire protection system form licensing agency twice in a year (in the month of January & July) & produce the Form 'B' certificate to this department.
 3. School management shall trained all staff members to operate the Fire Extinguisher.
- Issued on **23-09-2024** at Navi Mumbai by



Signature with Seal : 

Name : Vijay S. Rane

Designation : Chief Fire Officer

Name & Address of Department/ Office: Fire Department CIDCO

To

SHREE SWAMINARAYAN GURUKUL INTERNATIONAL SCHOOL
NH-4 Kandroli Village, Asarevadi Road, Chowk Post, Ta. Khalapur,
Dist.Raigad Maharastra – 410206