



ಕರ್ನಾಟಕ ಸರ್ಕಾರ

Health & Family welfare Department

Primary health center Kumbalagodu, Bangalore south taluk

No:PHC/KBL/24 /2023-24

Date:06/02/2024

Sanitation And safe drinking water certificate

It is to certified that an inspection team headed by **Dr Shalini D. Medical officer, PHC Kumbalagodu, Bangalore south taluk, Bangalore urban Dist.** Inspected the **SWAMINARAYAN INTERNATIONAL SCHOOL, next to Pepsi factory, Mysore road, kumbalagodu, Bangalore 560074.** On 30-01-2024, Lab No:PHC/KBL/Lab/01/Feb-24 and Tested the sample on 01-02-2024, result found that the SPP (Safe drinking Water) Facilities and Good Sanitation & Environment for the students and members of staff of Institution.

(Up to 3 months valid, from the tested date.)

Name of the Doctor: Dr Shalini D

Designation : Medical Officer

MEDICAL OFFICER
Primary Health Centre
Kumbalagodu, Bengaluru South Taluk
Bengaluru Urban District, Bengaluru-74

Signature

ಪ್ರಾಥಮಿಕ ಆರೋಗ್ಯ ಕೇಂದ್ರ
ಕುಂಬಲಗುಡು, ಬೆಂಗಳೂರು ದಕ್ಷಿಣ ತಾಲ್ಲೂಕು
ಬೆಂಗಳೂರು ನಗರ ಜಿಲ್ಲೆ ಬೆಂಗಳೂರು-74

Ramanagara District Water Quality Testing Laboratory

Office of Executive Engineer, Rural Drinking Water & Sanitation Division,
3rd Floor, ZillaPanchayathBhawan, Ramanagara - 562159, Karnataka.
Email: rdwsd.wqmssp.ramanagarlab@gmail.com



TEST REPORT

Address of the sampling location:

Swaminarayan Internatoinal School,
Mysore Road, PO: Kumbalagodu, Kanaminike,
Bangalore-560074, Karnataka,
Ramanagara Taluk & Ramanagara District.

ULR No. : TC123112400000201F

Report date: 24.01.2024

Reference: Sample receipt form

Sample receipt date: 23.01.2024

Sample code: RNG24JAN0201-P

Date of sample collection: 23.01.2024

Analysis start date: 24.01.2024

Analysis completion date: 24.01.2024

Sample collection protocol: APHA24th Edition

Sample Particulars: Drinking Water (RO)

Sample quantity: 1 Litre

Sl.No	Test	Results	Acceptable Limit IS 10500 :2012	Permissible Limit IS 10500 : 2012	Protocol
Description: Colourless liquid.					
1.	pH Value @25 °C	7.36	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Electrical Conductivity, $\mu\text{S}/\text{cm}$ @25 °C	126	–	–	IS 3025 (Part-14) : 2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Colour, Hazen Units	05	5	15	IS 3025 (Part-4) :2021
5.	Turbidity, NTU	< 0.5	1	5	IS 3025 (Part-10) : 2023
6.	Total Dissolved Solids @ 180°C, mg/l	88	500	2000	IS 3025 (Part-16) : 2023
7.	Alkalinity as CaCO_3 , mg/l	44.22	200	600	IS 3025 (Part-23) : 2023
8.	Total Hardness as CaCO_3 , mg/l	76.06	200	600	IS 3025 (Part-21) : 2002
9.	Calcium as Ca, mg/l	14.42	75	200	IS 3025 (Part-40) : 1991
10.	Magnesium as Mg, mg/l	9.72	30	100	IS 3025 (Part-46) : 2023
11.	Chloride as Cl, mg/l	65	250	1000	IS 3025 (Part-32) : 1988
12.	Sulphate as SO_4 , mg/l	16.60	200	400	IS 3025 (Part-24/Sec 1) : 2022
13.	Fluoride as F, mg/l	1.07	1	1.5	APHA 24 th Edition 4500- F D
14.	Nitrate as NO_3 , mg/l	5.86	45	No relaxation	APHA 24 th Edition 4500- NO_3B
15.	Iron as Fe, mg/l	< 0.1	1	No relaxation	IS 3025 (Part-53) : 2003

Remarks: The given sample conforms to the permissible limits of IS 10500 : 2012 Drinking Water Specification for the above tested parameters only.

RDWSD
Water Quality Lab
Ramanagara.

Reviewed By

Deepika

Authorized Signatory

(Deepika N D, Technical Manager)

RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

-:End of Report:-



SHREE SWAMINARAYAN GURUKUL SWAMINARAYAN INTERNATIONAL SCHOOL

Mysore Road, PO: Kumbalgodu, Kanaminike, Bangalore-560074, Karnataka, India
Ph: +91 98451 95000, 98458 98000 • www.gurukul.org • E-mail: bangalore@gurukul.org

Clarification

To Whom so ever It May Concern,

We, Swaminarayan International School, hereby Clarifying against your query that, there is no local body of PHE department available in surrounding to our school. Hence we are uploading the 'Water and Sanitation Certificate' issued by PHC Department on our website.

Regarding Testing Report: Our local government authority i.e, 'District Water Quality Testing laboratory' has issued the Test report, uploaded herewith in our website.

Correspondent Signature

Director

Shree Swaminarayan Gurukul .

Principal Signature

Principal

Swaminarayan International School

Mysore Road Bangalore - 560 074

